

Dry Slip Test Certificate

Wednesday December 23rd, 2020

Supplier: Australian Select Timbers PTY LTD (136 Atlas Boulevard, Dandenong South, VIC, 3175, Australia)

Sample Description: Hickory Impressions

Date Tested: April 2015 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: AS/NZS 4586-2013 Appendix B "Slip resistance classification of new pedestrian surface materials – Dry Floor Friction Test Method" using Slider 96

Test Data:


Sample Identification	Coefficient of Friction (COF): ¹	Classification ² (Classification of Pedestrian Surface materials Accordance to The AS 4586 Dry Floor Friction Test)
Hickory Impressions	0.49	D1

¹ Two test average value.

² The classification indicates that the contribution of the floor surfaces to the risk of slipping when dry is low.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Srikanth C. Srivatsa
PhD (Chemistry)
Consultant



Tuan Duong
PhD (Chemical Engineer)
Senior Consultant

CV140326 A